


CERTIFICATE

Of Electrical Appliance Testing

This Certificate confirms that

The electrical appliances on these premises (as per the current appliance register) have been inspected and tested for electrical safety to the IET's Code of Practice for In-service Inspection and Testing of Electrical Equipment.


Ian Bentall
Signer ID: LFCBUEB8P8...
04 Sep 2026, 19:56:36, BST

Certificate 26-016 Issued To:

Dave Hankins

Essex Booths

<https://hos35.uk/pat-certificates/?id=25019EPB>

Test Date:

September 2026


Technicians:

IanB

Certificate Issued By:

Harlow Online Services Ltd
35 Latton Bush Centre
Harlow
Essex
CM18 7BL
VAT No: GB 348 3815 76





Detailed Test Report

Dave Hankins

Essex Booths

Your electrical equipment testing was carried out by:

Harlow Online Services Ltd

35 Latton Bush Centre

Harlow Essex CM18 7BL

01279260600



Detailed Test Report

Generated: 4 Sep 2026 6:50 PM

Contained within this report:

1 site(s)	Essex Booths
1 location(s)	drop In
6 test(s)	6 asset(s)
5 test(s) passed	
1 test(s) failed	022

Site: Essex Booths

Location: drop In

Asset ID: 020 Description: 4 way extension lead Make: masterplug Serial #:

Asset Notes:

Date: 4 Sep 2026 Tested By: IanB Test Notes: Test Tag:

Result Type	Result	Unit	Status	Limit
Voltage	230	V	Information	
Fuse Rating	13	Amp	Information	
Insulation Voltage	500	V	Information	
Plug	0		Pass	
Flex	0		Pass	
Enclosure	0		Pass	
Environment	0		Pass	
Socket	0		Pass	
IEC Lead Continuity	0.43	Ohm	Pass	
IEC Lead Continuity	0.43	Ohm	Pass	
IEC Lead Continuity	0.43	Ohm	Pass	
IEC Lead Continuity	0.43	Ohm	Pass	



Detailed Test Report

Generated: 4 Sep 2026 6:50 PM

Site: Essex Booths

Location: drop In

Asset ID: 020 Description: 4 way extension lead Make: masterplug Serial #:

Asset Notes:

Date: 4 Sep 2026 Tested By: IanB Test Notes: Test Tag:

Result Type	Result	Unit	Status	Limit
Insulation	>19.99	MOhm	Pass	
IEC Lead Polarity			Pass	

Overall: Pass

Asset ID: 022 Description: iec lead Make: Serial #:

Asset Notes:

Date: 4 Sep 2026 Tested By: IanB Test Notes: poor earth lead Test Tag:

Result Type	Result	Unit	Status	Limit
Plug	0		Fail	
Flex	0		Fail	
Voltage	230	V	Information	

Overall: Fail

Asset ID: 023 Description: power supply Make: Serial #:

Asset Notes:

Date: 4 Sep 2026 Tested By: IanB Test Notes: Test Tag:

Result Type	Result	Unit	Status	Limit
Voltage	230	V	Information	
Insulation Voltage	500	V	Information	
Enclosure	0		Pass	
Environment	0		Pass	
Socket	0		Pass	



Detailed Test Report

Generated: 4 Sep 2026 6:50 PM

Site: Essex Booths

Location: drop In

Asset ID: 023 Description: power supply Make: Serial #:

Asset Notes:

Date: 4 Sep 2026 Tested By: IanB Test Notes: Test Tag:

Result Type	Result	Unit	Status	Limit
Insulation	>19.99	MOhm	Pass	

Overall: Pass

Asset ID: 024 Description: plug power block Make: asus Serial #:

Asset Notes:

Date: 4 Sep 2026 Tested By: IanB Test Notes: Test Tag:

Result Type	Result	Unit	Status	Limit
Voltage	230	V	Information	
Insulation Voltage	500	V	Information	
Plug	0		Pass	
Flex	0		Pass	
Enclosure	0		Pass	
Environment	0		Pass	
Insulation	>19.99	MOhm	Pass	

Overall: Pass

Asset ID: 025 Description: iec lead Make: Serial #:

Asset Notes:

Date: 4 Sep 2026 Tested By: IanB Test Notes: Test Tag:

Result Type	Result	Unit	Status	Limit
Voltage	230	V	Information	
Fuse Rating	10	Amp	Information	



Detailed Test Report

Generated: 4 Sep 2026 6:50 PM

Site: Essex Booths

Location: drop In

Asset ID: 025 Description: iec lead Make: Serial #:

Asset Notes:

Date: 4 Sep 2026 Tested By: IanB Test Notes: Test Tag:

Result Type	Result	Unit	Status	Limit
Insulation Voltage	500	V	Information	
Plug	0		Pass	
Flex	0		Pass	
Enclosure	0		Pass	
Environment	0		Pass	
Socket	0		Pass	
IEC Lead Continuity	0.06	Ohm	Pass	
Insulation	>19.99	MOhm	Pass	
IEC Lead Polarity			Pass	

Overall: Pass

Asset ID: 202 Description: printer Make: dnp Serial #:

Asset Notes:

Date: 4 Sep 2026 Tested By: IanB Test Notes: Test Tag:

Result Type	Result	Unit	Status	Limit
Voltage	230	V	Information	
Fuse Rating	10	Amp	Information	
Insulation Voltage	250	V	Information	
Plug	0		Pass	
Flex	0		Pass	
Enclosure	0		Pass	



Detailed Test Report

Generated: 4 Sep 2026 6:50 PM

Site: Essex Booths

Location: drop In

Asset ID: 202 Description: printer Make: dnp Serial #:

Asset Notes:

Date: 4 Sep 2026 Tested By: IanB Test Notes: Test Tag:

Result Type	Result	Unit	Status	Limit
Environment	0		Pass	
Socket	0		Pass	
Switch	0		Pass	
Earth Continuity	0.06	Ohm	Pass	
Insulation	>19.99	MOhm	Pass	
Substitute Leakage	0.05	mA	Pass	

Overall: Pass